



PRODUCT PERFORMANCE RATING

Document ID 1789112303-3d-b288df3a

Issued on: 11 September 2026 - Délivré le : 11 septembre 2026

This product is certified by Eurovent Certita Certification as mentioned on:

Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :



Certificate N° 17.04.002

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

Certification programmes / Programmes de certification

Product type / Type de produit

Model name / Nom du modèle

Range / Gamme

Participant / Titulaire

Brand / Marque

Air conditioners

Air to air, split, reversible (≤ 12 kW)

EXH-12RE1N-O/EX-12RE1N-I

Raynor

GD MIDEA Air-Conditioning Equipment Co. Ltd

MIDEA

This performance certificate is delivered for the following project

Project company	Project location
<i>Nom de la société</i>	<i>Localisation du projet</i>
MB Ex novo	Lithuania



PRODUCT PERFORMANCE RATING

Document ID 1789112303-3d-b288df3a

Issued on: 11 September 2026 - Délivré le : 11 septembre 2026

This product is certified by Eurovent Certita Certification as mentioned on:

Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :



Certificate N° 17.04.002

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

FEATURE	VALUE	UNIT
Standard Cooling/Cooling PL Cond A		
Pc	3.5	kW
(EN 14511:2022 Total Cooling Capacity at standard conditions / Part Load condition A @ 35°C)	4.7	
EER	0.74	kW
(EN 14511:2022 Energy Efficiency Ratio at standard conditions / Part Load condition A @ 35°C)		
Pec (Electric Power Input at standard conditions / Part Load condition A @ 35°C)		
Standard Heating		
Ph (EN 14511:2022 Total heating capacity at standard conditions @ +7°C Average Climate)	4.2	kW
Peh (Electric Power Input at standard conditions @ +7°C Average Climate)	0.95	kW
COP	4.42	
Seasonal Efficiency In Cooling		
Pdesignc (Design Load in cooling mode)	3.5	kW
SEER (Seasonal Energy Efficiency Ratio)	9	
SEER Class (Seasonal Energy Efficiency Ratio Class)	A+++	
Qce (Annual electricity consumption in cooling mode)	137	kWh/annum
Cooling PL Cond B		
Pc PL CondB (EN 14825:2022 Total Cooling Capacity Part Load condition B @ 30°C)	2.5	kW
EER PL CondB (EN 14825:2022 Energy Efficiency Ratio Part Load conditions B @ 30°C)	7.2	
Cooling PL Cond C		
Pc PL CondC (EN 14825:2022 Total Cooling Capacity Part Load condition C @ 25°C)	1.65	kW
EER PL CondC (EN 14825:2022 Energy Efficiency Ratio Part Load conditions C @ 25°C)	9.9	
Cooling PL Cond D		
Pc PL CondD (EN 14825:2022 Total Cooling Capacity Part Load condition D @ 20°C)	1	kW
EER PL CondD (EN 14825:2022 Energy Efficiency Ratio Part Load conditions D @ 20°C)	16.5	
Seasonal Coefficient Of Performance		
Pdesignh (Design Load in heating mode Average Climate)	4	kW
SCOP (Seasonal Coefficient of Performance Average Climate)	5.1	
SCOP Class (Seasonal Coefficient of Performance Class Average Climate)	A+++	
Qhe (Annual electricity consumption in heating mode)	1099	kWh/annum
Heating PL Cond A		
Ph PL CondA	3.54	kW
(EN 14825:2022 Total heating capacity Part Load condition A @ -7°C Average Climate)		
COP PL CondA		



PRODUCT PERFORMANCE RATING

Document ID 1789112303-3d-b288df3a

Issued on: 11 September 2026 - Délivré le : 11 septembre 2026

This product is certified by Eurovent Certita Certification as mentioned on:

Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :



Certificate N° 17.04.002

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

(EN 14825:2022 Coefficient of Performances Part Load condition A @ -7°C Average Climate)

3.3	
-----	--



PRODUCT PERFORMANCE RATING

Document ID 1789112303-3d-b288df3a

Issued on: 11 September 2026 - Délivré le : 11 septembre 2026

This product is certified by Eurovent Certita Certification as mentioned on:

Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :



Certificate N° 17.04.002

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

Heating PL Cond B		
Ph PL CondB	2.2	kW
(EN 14825:2022 Total heating capacity Part Load condition B @ +2°C Average Climate)	5.1	
COP PL CondB		
Heating PL Cond C		
Ph PL CondC	1.4	kW
(EN 14825:2022 Total heating capacity Part Load condition C @ +7°C Average Climate)	6.48	
COP PL CondC		
Heating PL Cond D		
Ph PL CondD	0.98	kW
(EN 14825:2022 Total heating capacity Part Load condition D @ +12°C Average Climate)	7.5	
COP PL CondD		
Heating PL Cond E TOL		
TOL (Operating LimitTemperature)	-10	°C
Ph PL CondE TOL	3.98	kW
(EN 14825:2022 Total heating capacity Part Load condition E @ TOL Average Climate)	2.6	
COP PL CondE TOL		
Heating PL Cond F Tbivalent		
Tbiv (Bivalent Temperature)	-7	°C
Ph PL CondF Tbiv	3.54	kW
(EN 14825:2022 Total heating capacity Part Load condition F @ TBiv Average Climate)	3.3	
COP PL CondF Tbiv		
Psbcc		
Psbcc (Power consumption in standby mode in cooling mode)	1	W
Poffcc		
Poffcc (Power consumption in off mode in cooling mode)	1	W
Ptoc		
Ptoc (Power consumption in thermostat off mode in cooling mode)	12	W
Pckc		
Pckc (Power consumption of the crankcase heater in cooling mode)	0	W
Psbh		
Psbh (Power consumption in standby mode in heating mode)	1	W
Poffh		
Poffh (Power consumption in off mode in heating mode)	1	W
Ptoh		
Ptoh (Power consumption in thermostat off mode in heating mode)	13	W



PRODUCT PERFORMANCE RATING

Document ID 1789112303-3d-b288df3a

Issued on: 11 September 2026 - Délivré le : 11 septembre 2026

This product is certified by Eurovent Certita Certification as mentioned on:

Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :



Certificate N° 17.04.002

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

Pckh		
Pckh (Power consumption of the crankcase heater in heating mode)	0	W
Seasonnal Coefficient Of Performance Colder Climate		
Pdesignh C (Design Load in heating mode Colder Climate)	4.2	kW
SCOP C (Seasonnal Coefficient of Performance Colder Climate)	4.6	
SCOP Class C (Seasonal Coefficient Of Performance Class Colder Climate)	A++	
Qhe C (Annual electricity consumption in heating mode Colder climate)	1918	kWh/annum
Heating PL Cond G Colder		
Ph PL CondG C	5.6	kW
(EN 14825:2022 Total heating capacity Part Load condition G @ -15°C Colder Climate)	1.9	
COP PL CondG C		
Heating PL Cond C Colder		
COP PL CondC C	6.24	
Heating PL Cond D Colder		
Ph PL CondD C	0.96	W
(EN 14825:2022 Total heating capacity Part Load condition A @ +12°C Colder Climate)	7.54	
COP PL CondD C		
Heating PL Cond E TOL Colder		
Ph PL CondE TOL C	4.18	kW
Seasonnal Coefficient Of Performance Warmer Climate		
SCOP W (Seasonnal Coefficient of Performance Warmer Climate)	6.5	
SCOP Class W (Seasonal Coefficient Of Performance Class Warmer Climate)	A+++	
Qhe W (Annual electricity consumption in heating mode Warmer climate)	690	kWh/annum
Acoustic In Cooling		
LwO env (EN 12102-1:2022 A-weighted sound power level outdoor unit (non ducted))	62	dB(A)
LwI1 env (EN 12102-1:2022 A-weighted sound power level indoor unit 1 (non ducted))	59	dB(A)
General		
IU Names (Names of combinable Indoor units)	EX-12RE1N-I	
No. of IU (Number of indoor units)	1	
IU Range Names (Range Names of combinable Indoor units)	Raynor	
Mounting (Mounting Type)	wall-mounted	
Refrigerant	R32	
Factory Refrigerant Charge (Factory refrigerant charge)	1	kg



PRODUCT PERFORMANCE RATING

Document ID 1789112303-3d-b288df3a

Issued on: 11 September 2026 - Délivré le : 11 septembre 2026

This product is certified by Eurovent Certita Certification as mentioned on:

Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :



Certificate N° 17.04.002

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

FEATURE	VALUE	UNIT
General		
Refr. Line (Refrigerant Line. If possible)	5	m
Main Power Supply (Voltage (V) - Phase - Frequency (Hz))	230-1-50	
Capacity Control	variable	
Eligible CEE		
Eligible CEE	true	

(this item provide information if the unit is eligible to the certificat d'economie d'energie)

Air Conditioners / Climatiseurs

Comfort Air Conditioners rated up to or equal to 12kW (AC1≤12 kW)// Climatiseurs plus petit ou égal à 12kW (AC1≤12 kW)

Granted on April 18, 2017 - Date 1ère admission 18 avril 2017

This document is valid at the date of issue - Check the current validity on:
Document valable à la date d'émission - Vérifier la validité en cours sur :
www.eurovent-certification.com

Participant/Titulaire

GD MIDEA Air-Conditioning Equipment Co. Ltd
Midea Industrial City - Lingang road - Beijiao - Shunde
528311 Foshan, Guangdong, China

This product performance certificate is issued by Eurovent Certita Certification according to the certification rules:

ECP AC - « Air Conditioners » in force at established date.

Pursuant to the decision notified by Eurovent Certita Certification, the right to use the mark ECP shall be granted to the beneficiary company for all products inside the defined scope according to "certify-all" principle and in the conditions defined by the certification program mentioned.

Unless withdrawn or suspended, this certificate remains valid as long as the requirements for the certification program framework are met. The validity of the certificate is to be verified on www.eurovent-certification.com

THIS CERTIFICATE HAS BEEN ISSUED ON 07/05/2026
THIS CERTIFICATE IS VALID UNTIL 31/07/2027

Ce certificat de performance produit est délivré par Eurovent Certita Certification dans les conditions fixées par le référentiel :

ECP AC – « Climatiseurs » en vigueur à date d'édition.

En vertu de la décision notifiée par Eurovent Certita Certification, le droit d'usage de la marque ECP, est accordé à la société qui en est bénéficiaire pour tous les produits entrant dans le champ d'application défini selon le principe "certify-all" et dans les conditions définies par le programme de certification mentionné.

Sauf retrait ou suspension, ce certificat demeure valide tant que les conditions du référentiel du programme de certification sont respectées. La validité du certificat est à vérifier sur le site Internet www.eurovent-certification.com

CE CERTIFICAT A ÉTÉ EMIS LE 07/05/2026
CE CERTIFICAT EST VALIDE JUSQU'AU 31/07/2027

Paris, 7 mai 2026

MANAGING BOARD MEMBER / MEMBRE DIRECTOIRE



Appendix / Annexe

Granted on April 18, 2017 - *Date 1ère admission 18 avril 2017*

This document is valid at the date of issue - Check the current validity on:
Document valable à la date d'émission - Vérifier la validité en cours sur :
www.eurovent-certification.com

List of certified products and characteristics is displayed on:
La liste des références et caractéristiques certifiées est disponible sur le site :
[**www.eurovent-certification.com**](http://www.eurovent-certification.com)

This product performance certificate is valid for the following trade names:
Ce certificat de performance produit est valide pour les marques commerciales suivantes:
[Trade Name / Marque Commerciale](#)

MIDEA

This product performance certificate is valid for the following manufacturing places:
Ce certificat de performance produit est valide pour les sites de production suivants:
[Manufacturing Place / Site de Production](#)

Not applicable for this certification programme / Non applicable pour ce programme de certification

This product performance certificate is valid for the following software:
Ce certificat de performance produit est valide pour les logiciels de sélection suivants:
[Software / Logiciel de sélection](#)

Not applicable for this certification programme / Non applicable pour ce programme de certification