

Information requirements (heat pump space heaters and heat pump combination heaters)							
Model(s): GRS-CQ10PdG/NhH3-E							
Air-to-water heat pump	Y			Low-temperature heat pump	N		
Water-to-water heat pump	N			Equipped with a supplementary heater	Y		
Brine-to-water heat pump	N			Heat pump combination heater	Y		
Parameters declared for	Medium-temperature application						
Parameters declared for	Average climate condition						
Item	symbol	value	unit	Item	symbol	value	unit
Rated heat output (*)	Prated	9	kW	Seasonal space heating energy efficiency	ηs	130	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	7.65	kW	Tj = - 7 °C	COPd	2.29	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = 2 °C	Pdh	4.66	kW	Tj = 2 °C	COPd	3.24	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = 7 °C	Pdh	3.08	kW	Tj = 7 °C	COPd	4.17	-
Degradation co-efficient (**)	Cdh	0.97	-				
Tj = 12 °C	Pdh	3.21	kW	Tj = 12 °C	COPd	5.24	-
Degradation co-efficient (**)	Cdh	0.96	-				
Tj = bivalent temperature	Pdh	7.65	kW	Tj = bivalent temperature	COPd	2.29	-
Tj = operation limit temperature	Pdh	7.01	kW	Tj = operation limit temperature	COPd	2.07	-
For air-to-water heat pumps: Tj = - 15 °C (if TOL < - 20 °C)	Pdh	NA	kW	For air-to-water heat pumps: Tj = - 15 °C (if TOL < - 20 °C)	COPd	NA	-
Bivalent temperature	Tbiv	-7	°C	For air-to-water heat pumps: Operation limit temperature	TOL	-10	°C
Cycling interval capacity for heating	Ppsych	NA	kW	Cycling interval efficiency	COPcyc	NA	-
				Heating water operating limit temperature	WTOL	65	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.025	kW	Rated heat output (*)	Psup	1.99	kW
Thermostat-off mode	P _{TO}	0.025	kW	Type of energy input	Electric		
Standby mode	P _{SB}	0.025	kW				
Crankcase heater mode	P _{CK}	0	kW				
Other items							
Capacity control	variable			For air-to-water heat pumps: Rated air flow rate, outdoors	-	4972	m ³ / h
Sound power level, outdoors	L _{WA}	64	dB	For water- or brine-to-water heat pumps: Rated brine or water flow rate, outdoor heat exchanger	-	NA	m ³ / h
Annual energy consumption	Q _{HE}	5344	kWh				
For heat pump combination heater:							
Declared load profile	L			Water heating energy efficiency	η _{wh}	123	%
Daily electricity consumption	Q _{elec}	3.985	kWh	Daily fuel consumption	Q _{fuel}	NA	kWh
Annual electricity consumption	AEC	831	kWh	Annual fuel consumption	AFC	NA	GJ
Contact details: West Jinji Rd, Qianshan, Zhuhai, Guangdong, China, 519070				Name of the supplier: GREE ELECTRIC APPLIANCES,INC. OF ZHUHAI			
(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj). (**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.							

Information requirements (heat pump space heaters and heat pump combination heaters)							
Model(s): GRS-CQ10PdG/NhH3-E							
Air-to-water heat pump	Y			Low-temperature heat pump	N		
Water-to-water heat pump	N			Equipped with a supplementary heater	Y		
Brine-to-water heat pump	N			Heat pump combination heater	Y		
Parameters declared for	Medium-temperature application						
Parameters declared for	Colder climate condition						
Item	symbol	value	unit	Item	symbol	value	unit
Rated heat output (*)	Prated	8	kW	Seasonal space heating energy efficiency	ηs	111	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	5.25	kW	Tj = - 7 °C	COPd	2.39	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = 2 °C	Pdh	3.19	kW	Tj = 2 °C	COPd	3.39	-
Degradation co-efficient (**)	Cdh	0.97	-				
Tj = 7 °C	Pdh	2.43	kW	Tj = 7 °C	COPd	4.94	-
Degradation co-efficient (**)	Cdh	0.95	-				
Tj = 12 °C	Pdh	3.26	kW	Tj = 12 °C	COPd	5.61	-
Degradation co-efficient (**)	Cdh	0.96	-				
Tj = bivalent temperature	Pdh	6.44	kW	Tj = bivalent temperature	COPd	1.65	-
Tj = operation limit temperature	Pdh	5.19	kW	Tj = operation limit temperature	COPd	1.22	-
For air-to-water heat pumps: Tj = - 15 °C (if TOL < - 20 °C)	Pdh	6.44	kW	For air-to-water heat pumps: Tj = - 15 °C (if TOL < - 20 °C)	COPd	1.65	-
Bivalent temperature	Tbiv	-15	°C	For air-to-water heat pumps: Operation limit temperature	TOL	-22	°C
Cycling interval capacity for heating	Ppsych	NA	kW	Cycling interval efficiency	COPcyc	NA	-
				Heating water operating limit temperature	WTOL	65	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.025	kW	Rated heat output (*)	Psup	2.81	kW
Thermostat-off mode	P _{TO}	0.025	kW	Type of energy input	Electric		
Standby mode	P _{SB}	0.025	kW				
Crankcase heater mode	P _{CK}	0	kW				
Other items							
Capacity control	variable			For air-to-water heat pumps: Rated air flow rate, outdoors	-	4972	m ³ / h
Sound power level, outdoors	L _{WA}	64	dB	For water- or brine-to-water heat pumps: Rated brine or water flow rate, outdoor heat exchanger	-	NA	m ³ / h
Annual energy consumption	Q _{HE}	6820	kWh				
For heat pump combination heater:							
Declared load profile	L			Water heating energy efficiency	η _{wh}	94	%
Daily electricity consumption	Q _{elec}	5.175	kWh	Daily fuel consumption	Q _{fuel}	NA	kWh
Annual electricity consumption	AEC	1090	kWh	Annual fuel consumption	AFC	NA	GJ
Contact details: West Jinji Rd, Qianshan, Zhuhai, Guangdong, China, 519070				Name of the supplier: GREE ELECTRIC APPLIANCES, INC. OF ZHUHAI			
(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj). (**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.							

Information requirements (heat pump space heaters and heat pump combination heaters)							
Model(s): GRS-CQ10PdG/NhH3-E							
Air-to-water heat pump	Y			Low-temperature heat pump	N		
Water-to-water heat pump	N			Equipped with a supplementary heater	Y		
Brine-to-water heat pump	N			Heat pump combination heater	Y		
Parameters declared for	Medium-temperature application						
Parameters declared for	Warmer climate condition						
Item	symbol	value	unit	Item	symbol	value	unit
Rated heat output (*)	Prated	10	kW	Seasonal space heating energy efficiency	ηs	162	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	NA	kW	Tj = - 7 °C	COPd	NA	-
Degradation co-efficient (**)	Cdh	NA	-				
Tj = 2 °C	Pdh	9.51	kW	Tj = 2 °C	COPd	2.47	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = 7 °C	Pdh	5.84	kW	Tj = 7 °C	COPd	3.56	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = 12 °C	Pdh	2.76	kW	Tj = 12 °C	COPd	5.15	-
Degradation co-efficient (**)	Cdh	0.95	-				
Tj = bivalent temperature	Pdh	9.51	kW	Tj = bivalent temperature	COPd	2.47	-
Tj = operation limit temperature	Pdh	9.51	kW	Tj = operation limit temperature	COPd	2.47	-
For air-to-water heat pumps: Tj = - 15 °C (if TOL < - 20 °C)	Pdh	NA	kW	For air-to-water heat pumps: Tj = - 15 °C (if TOL < - 20 °C)	COPd	NA	-
Bivalent temperature	Tbiv	2	°C	For air-to-water heat pumps: Operation limit temperature	TOL	2	°C
Cycling interval capacity for heating	Ppsych	NA	kW	Cycling interval efficiency	COPcyc	NA	-
				Heating water operating limit temperature	WTOL	65	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.025	kW	Rated heat output (*)	Psup	0.49	kW
Thermostat-off mode	P _{TO}	0.025	kW	Type of energy input	Electric		
Standby mode	P _{SB}	0.025	kW				
Crankcase heater mode	P _{CK}	0	kW				
Other items							
Capacity control	variable			For air-to-water heat pumps: Rated air flow rate, outdoors	-	4972	m ³ / h
Sound power level, outdoors	L _{WA}	64	dB	For water- or brine-to-water heat pumps: Rated brine or water flow rate, outdoor heat exchanger	-	NA	m ³ / h
Annual energy consumption	Q _{HE}	3074	kWh				
For heat pump combination heater:							
Declared load profile	L			Water heating energy efficiency	η _{wh}	143	%
Daily electricity consumption	Q _{elec}	3.429	kWh	Daily fuel consumption	Q _{fuel}	NA	kWh
Annual electricity consumption	AEC	717	kWh	Annual fuel consumption	AFC	NA	GJ
Contact details: West Jinji Rd, Qianshan, Zhuhai, Guangdong, China, 519070				Name of the supplier: GREE ELECTRIC APPLIANCES,INC. OF ZHUHAI			
(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj). (**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.							

Information requirements (heat pump space heaters and heat pump combination heaters)							
Model(s): GRS-CQ10PdG/NhH3-E							
Air-to-water heat pump	Y			Low-temperature heat pump	N		
Water-to-water heat pump	N			Equipped with a supplementary heater	Y		
Brine-to-water heat pump	N			Heat pump combination heater	Y		
Parameters declared for	Low-temperature application						
Parameters declared for	Average climate condition						
Item	symbol	value	unit	Item	symbol	value	unit
Rated heat output (*)	Prated	9	kW	Seasonal space heating energy efficiency	ηs	182	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	7.76	kW	Tj = - 7 °C	COPd	3.15	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = 2 °C	Pdh	4.90	kW	Tj = 2 °C	COPd	4.59	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = 7 °C	Pdh	3.04	kW	Tj = 7 °C	COPd	5.67	-
Degradation co-efficient (**)	Cdh	0.95	-				
Tj = 12 °C	Pdh	3.28	kW	Tj = 12 °C	COPd	7.34	-
Degradation co-efficient (**)	Cdh	0.94	-				
Tj = bivalent temperature	Pdh	7.76	kW	Tj = bivalent temperature	COPd	3.15	-
Tj = operation limit temperature	Pdh	7.14	kW	Tj = operation limit temperature	COPd	2.76	-
For air-to-water heat pumps: Tj = - 15 °C (if TOL < - 20 °C)	Pdh	NA	kW	For air-to-water heat pumps: Tj = - 15 °C (if TOL < - 20 °C)	COPd	NA	-
Bivalent temperature	Tbiv	-7	°C	For air-to-water heat pumps: Operation limit temperature	TOL	-10	°C
Cycling interval capacity for heating	Ppsych	NA	kW	Cycling interval efficiency	COPcyc	NA	-
				Heating water operating limit temperature	WTOL	65	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.025	kW	Rated heat output (*)	Psup	1.86	kW
Thermostat-off mode	P _{TO}	0.025	kW	Type of energy input	Electric		
Standby mode	P _{SB}	0.025	kW				
Crankcase heater mode	P _{CK}	0	kW				
Other items							
Capacity control	variable			For air-to-water heat pumps: Rated air flow rate, outdoors	-	4972	m ³ / h
Sound power level, outdoors	L _{WA}	64	dB	For water- or brine-to-water heat pumps: Rated brine or water flow rate, outdoor heat exchanger	-	NA	m ³ / h
Annual energy consumption	Q _{HE}	3912	kWh				
For heat pump combination heater:							
Declared load profile	L			Water heating energy efficiency	η _{wh}	123	%
Daily electricity consumption	Q _{elec}	3.985	kWh	Daily fuel consumption	Q _{fuel}	NA	kWh
Annual electricity consumption	AEC	831	kWh	Annual fuel consumption	AFC	NA	GJ
Contact details: West Jinji Rd, Qianshan, Zhuhai, Guangdong, China, 519070				Name of the supplier: GREE ELECTRIC APPLIANCES,INC. OF ZHUHAI			
(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj). (**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.							

Information requirements (heat pump space heaters and heat pump combination heaters)							
Model(s): GRS-CQ10PdG/NhH3-E							
Air-to-water heat pump	Y			Low-temperature heat pump	N		
Water-to-water heat pump	N			Equipped with a supplementary heater	Y		
Brine-to-water heat pump	N			Heat pump combination heater	Y		
Parameters declared for	Low-temperature application						
Parameters declared for	Colder climate condition						
Item	symbol	value	unit	Item	symbol	value	unit
Rated heat output (*)	Prated	8	kW	Seasonal space heating energy efficiency	ηs	149	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	5.22	kW	Tj = - 7 °C	COPd	3.62	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = 2 °C	Pdh	3.27	kW	Tj = 2 °C	COPd	4.29	-
Degradation co-efficient (**)	Cdh	0.97	-				
Tj = 7 °C	Pdh	2.53	kW	Tj = 7 °C	COPd	5.31	-
Degradation co-efficient (**)	Cdh	0.95	-				
Tj = 12 °C	Pdh	3.33	kW	Tj = 12 °C	COPd	6.84	-
Degradation co-efficient (**)	Cdh	0.95	-				
Tj = bivalent temperature	Pdh	6.46	kW	Tj = bivalent temperature	COPd	2.72	-
Tj = operation limit temperature	Pdh	3.15	kW	Tj = operation limit temperature	COPd	1.43	-
For air-to-water heat pumps: Tj = - 15 °C (if TOL < - 20 °C)	Pdh	6.46	kW	For air-to-water heat pumps: Tj = - 15 °C (if TOL < - 20 °C)	COPd	2.72	-
Bivalent temperature	Tbiv	-15	°C	For air-to-water heat pumps: Operation limit temperature	TOL	-22	°C
Cycling interval capacity for heating	Ppsych	NA	kW	Cycling interval efficiency	COPcyc	NA	-
				Heating water operating limit temperature	WTOL	65	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.025	kW	Rated heat output (*)	Psup	4.85	kW
Thermostat-off mode	P _{TO}	0.025	kW	Type of energy input	Electric		
Standby mode	P _{SB}	0.025	kW				
Crankcase heater mode	P _{CK}	0	kW				
Other items							
Capacity control	variable			For air-to-water heat pumps: Rated air flow rate, outdoors	-	4972	m ³ / h
Sound power level, outdoors	L _{WA}	64	dB	For water- or brine-to-water heat pumps: Rated brine or water flow rate, outdoor heat exchanger	-	NA	m ³ / h
Annual energy consumption	Q _{HE}	5105	kWh				
For heat pump combination heater:							
Declared load profile	L			Water heating energy efficiency	η _{wh}	94	%
Daily electricity consumption	Q _{elec}	5.175	kWh	Daily fuel consumption	Q _{fuel}	NA	kWh
Annual electricity consumption	AEC	1090	kWh	Annual fuel consumption	AFC	NA	GJ
Contact details: West Jinji Rd, Qianshan, Zhuhai, Guangdong, China, 519070				Name of the supplier: GREE ELECTRIC APPLIANCES,INC. OF ZHUHAI			
(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj). (**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.							

Information requirements (heat pump space heaters and heat pump combination heaters)							
Model(s): GRS-CQ10PdG/NhH3-E							
Air-to-water heat pump	Y			Low-temperature heat pump	N		
Water-to-water heat pump	N			Equipped with a supplementary heater	Y		
Brine-to-water heat pump	N			Heat pump combination heater	Y		
Parameters declared for	Low-temperature application						
Parameters declared for	Warmer climate condition						
Item	symbol	value	unit	Item	symbol	value	unit
Rated heat output (*)	Prated	10	kW	Seasonal space heating energy efficiency	ηs	235	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = − 7 °C	Pdh	NA	kW	Tj = − 7 °C	COPd	NA	−
Degradation co-efficient (**)	Cdh	NA	−				
Tj = 2 °C	Pdh	9.55	kW	Tj = 2 °C	COPd	3.39	−
Degradation co-efficient (**)	Cdh	0.99	−				
Tj = 7 °C	Pdh	5.83	kW	Tj = 7 °C	COPd	5.18	−
Degradation co-efficient (**)	Cdh	0.98	−				
Tj = 12 °C	Pdh	2.78	kW	Tj = 12 °C	COPd	7.48	−
Degradation co-efficient (**)	Cdh	0.93	−				
Tj = bivalent temperature	Pdh	9.55	kW	Tj = bivalent temperature	COPd	3.39	−
Tj = operation limit temperature	Pdh	9.55	kW	Tj = operation limit temperature	COPd	3.39	−
For air-to-water heat pumps: Tj = − 15 °C (if TOL < − 20 °C)	Pdh	NA	kW	For air-to-water heat pumps: Tj = − 15 °C (if TOL < − 20 °C)	COPd	NA	−
Bivalent temperature	Tbiv	2	°C	For air-to-water heat pumps: Operation limit temperature	TOL	2	°C
Cycling interval capacity for heating	Ppsych	NA	kW	Cycling interval efficiency	COPcyc	NA	−
				Heating water operating limit temperature	WTOL	65	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.025	kW	Rated heat output (*)	Psup	0.45	kW
Thermostat-off mode	P _{TO}	0.025	kW	Type of energy input	Electric		
Standby mode	P _{SB}	0.025	kW				
Crankcase heater mode	P _{CK}	0	kW				
Other items							
Capacity control	variable			For air-to-water heat pumps: Rated air flow rate, outdoors	−	4972	m ³ /h
Sound power level, outdoors	L _{WA}	64	dB	For water- or brine-to-water heat pumps: Rated brine or water flow rate, outdoor heat exchanger	−	NA	m ³ /h
Annual energy consumption	Q _{HE}	2138	kWh				
For heat pump combination heater:							
Declared load profile	L			Water heating energy efficiency	η _{wh}	143	%
Daily electricity consumption	Q _{elec}	3.429	kWh	Daily fuel consumption	Q _{fuel}	NA	kWh
Annual electricity consumption	AEC	717	kWh	Annual fuel consumption	AFC	NA	GJ
Contact details: West Jinji Rd, Qianshan, Zhuhai, Guangdong, China, 519070				Name of the supplier: GREE ELECTRIC APPLIANCES,INC. OF ZHUHAI			
(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj). (**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.							



600081060431